

# Display energy certificate (DEC)



North Hertfordshire District Council  
North Hertfordshire District Council  
Council Offices, Gernon Road  
Letchworth Garden City  
SG6 3JF

Operational rating

**B**

Certificate number: 9991-7231-3190-7271-2290

Valid until: 28 December 2021

Total useful floor area: 3156.68 square metres

## Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO<sub>2</sub>) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	<b>A</b>		
26-50	<b>B</b>	<b>44   B</b>	
51-75	<b>C</b>		
76-100	<b>D</b>		
			100
101-125	<b>E</b>		
126-150	<b>F</b>		
150+	<b>G</b>		

## This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m <sup>2</sup> /year)	48.92	27.22
Typical energy use (kWh/m <sup>2</sup> /year)	95	104.23
Energy from renewables	0.0%	0.0%

## Previous operational ratings

Date	Operational rating
December 2020	<b>44   B</b>
December 2019	<b>50   B</b>
January 2019	<b>52   C</b>

## Total carbon dioxide (CO<sub>2</sub>) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO<sub>2</sub>.

Date	Electricity	Heating	Renewables
December 2020	85	17	0
December 2019	98	18	0
January 2019	87	34	0

## Assessment details

Assessor's name: Alistair Alcock

Accreditation scheme: Stroma Certification Ltd

Employer/Trading name: School Energy Matters Ltd  
07795015118

Employer/Trading address: 30 Albert Road, FY8 3SU

Issue date: 1 December 2020

Nominated date: 29 December 2020

Assessor's declaration: Not related to the occupier.